



NOTES: LENGTH AS REQUIRED TO PUT OPERATING NUT, TWO (2) FEET FROM SURFACE.
 EXTENSIONS ARE REQUIRED WHEN THE VALVE NUT IS MORE THAN FOUR (4) FEET
 BELOW FINISHED GRADE. EXTENSIONS ARE TO BE A MINIMUM OF TWO (2) FEET
 LONG. ONE EXTENSION IS TO BE USED PER VALVE.

ALL EXTENSIONS ARE TO BE MADE OF STEEL, SIZED AS NOTED, AND PAINTED
 WITH TWO (2) COATS OF ENAMEL PAINT.

VALVE OPERATING NUT EXTENSION
 NTS



REVISION DATE 3/1/04	DRAWN SED	CHECKED TDK	DISTRICT APPROVED TDK
PLOTTING SCALE NTS	FILE NAME F:\DWGS\DETAILS-2004\HWD-025	DATE APPROVED 3/1/04	