

NOTES

1. CONTRACTOR SHALL VERIFY ALL EXISTING UTILITIES IN THE FIELD.
2. CONTRACTOR SHALL NOTIFY DISTRICT A MINIMUM OF 72 HOURS (3 WORKING DAYS) IN ADVANCE OF ALL REQUESTS FOR STAKING, TESTING OR INSPECTIONS.
3. DEVELOPER'S REGISTERED PROFESSIONAL LAND SURVEYOR SHALL PROVIDE STAKING OF WATER SYSTEM CONSTRUCTION FOR DISTRICT INSPECTION A MINIMUM OF 72 HRS. PRIOR TO CONSTRUCTION.
4. CONTRACTOR SHALL FURNISH SHOP DRAWINGS FOR APPROVAL WHERE REQUIRED BY THE DETAIL SPECIFICATIONS AND FOR VARIATION FROM THE APPROVED DRAWING.
5. CONTRACTOR SHALL INSTALL EQUIPMENT IN ACCORDANCE WITH MANUFACTURERS' RECOMMENDATIONS AND HIGHLINE WATER DISTRICT SPECIFICATIONS.
6. CONTRACTOR TO FURNISH ALL MATERIALS.
7. ALL DUCTILE IRON PIPE SHALL BE CLASS 52, NO EQUAL.
8. ALL GATE VALVES SHALL BE MUELLER OR EQUIVALENT.
9. HYDRANTS SHALL BE AS SPECIFIED.
10. CUT-INS SHALL BE DIRECTLY SUPERVISED BY AN AUTHORIZED REPRESENTATIVE OF HIGHLINE WATER DISTRICT OR PREFORMED BY THE DISTRICT.
11. ALL LIVE TAPS SHALL BE DIRECTLY SUPERVISED BY AN AUTHORIZED REPRESENTATIVE OF HIGHLINE WATER DISTRICT.
12. ALL CHARGES FOR CUT-INS AND LIVE TAPS ARE THE RESPONSIBILITY OF THE DEVELOPER/CONTRACTOR.
13. ALL COUPLINGS SHALL BE ROMAC 501, OR EQUIVALENT.
14. CONTRACTOR IS RESPONSIBLE FOR VERIFYING ALL EXISTING PIPE TYPES AND SIZES FOR COUPLINGS, CONNECTIONS AND LIVE TAPS.
15. ALL MAINLINE PIPE SHALL HAVE A 42" MINIMUM COVER AND 60" MAXIMUM COVER UNLESS OTHERWISE SHOWN ON PLANS.
16. DEVELOPER SHALL PAY FOR ALL STATE, CITY, AND COUNTY INSPECTION AND PERMIT FEES.
17. COORDINATE METER LOCATIONS WITH HIGHLINE WATER DISTRICT AUTHORIZED REPRESENTATIVE.
18. FIRE HYDRANTS AND MAINS TO BE OPERATIONAL PRIOR TO COMMENCEMENT OF BUILDING CONSTRUCTION.
19. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE A SET OF THESE APPROVED PLANS ON THE JOB SITE WHENEVER CONSTRUCTION IS IN PROGRESS. NO CHANGES ARE TO BE MADE WITHOUT PRIOR WRITTEN APPROVAL BY THE DISTRICT.
20. SUBGRADE SHALL BE ESTABLISHED FOR AREAS OF SITE INVOLVING WATER SYSTEM FACILITIES.
21. PARTS MUST BE ON-SITE AND INSPECTED BY HIGHLINE WATER DISTRICT PRIOR TO SCHEDULING CUT-INS OR CONNECTIONS.
22. REFER TO HIGHLINE WATER DISTRICT DESIGN AND DEVELOPEMENT STANDARDS FOR ALL REMAINING NOTES AND DETAILS.
23. WATER USES OTHER THAN THOSE SHOWN WILL BE EVALUATED BY HIGHLINE WATER DISTRICT FOR COMPLIANCE WITH BACKFLOW PREVENTION REQUIREMENTS.
24. COMPACTION TESTING IS REQUIRED FOR ALL OPEN CUTS AND/OR CROSSINGS WITHIN PAVED OR TRAVELED AREAS OF PUBLIC RIGHT-OF-WAYS.
25. THE APPROVAL OF THESE PLANS DOES NOT RELIEVE THE CUSTOMER OF THE RESPONSIBILITY TO COMPLY WITH THE REQUIREMENTS OF OTHER AGENCIES AND, TO INSTALL ADDITIONAL BACKFLOW ASSEMBLIES RESULTING FROM THE DISTRICT'S FINAL SURVEY OF THE FACILITIES OR AT A FUTURE DATE SHOULD THE CUSTOMER HAVE A CHANGE IN USE OF THEIR WATER SYSTEM.
26. SEPARATION SHALL BE 10' HORIZONTAL FOR SANITARY SEWER, 5' HORIZONTAL FOR ALL OTHER UTILITIES. 18" VERTICAL CLEARANCE FOR SANITARY, 6" CLEARANCE FOR ALL OTHERS.

GENERAL NOTES



REVISION DATE 12/1/04	DRAWN SED	CHECKED TDK	DISTRICT APPROVED TDK
PLOTTING SCALE NTS	FILE NAME F:\DWGS\DETAILS-2000\HWD-028		DATE APPROVED 12/1/04