



NOTES:

- DDCVA INSIDE BUILDING ONLY BY APPROVAL OF DISTRICT ENGINEER.
- DDCVA SHALL BE ON THE WADOH APPROVED LIST
- INSTALL VALVE MARKER POST (SEE STANDARD DETAIL).
- INSTALL ALARM SYSTEM & FDC AS REQUIRED BY FIRE AUTHORITY.
- WATERPROOF PIPE ENTRY THROUGH WALLS WITH KRYPTON MORTAR SEALANT OR APPROVED EQUAL.
- SEE APPROVED MATERIALS LIST.
- BYPASS METER SHALL BE SUPPLIED AND OWNED BY THE DISTRICT.
- ALL MATERIALS DOWNSTREAM OF GATE VALVE AT EDGE OF EASEMENT/R.O.W. ARE PRIVATE AND THE RESPONSIBILITY OF THE OWNER (EXCEPT FOR BYPASS METER & RADIOHEAD).
- OWNER TO PROVIDE A RIGHT-OF-ENTRY AGREEMENT FOR DISTRICT ACCESS INTO BUILDING.
- OWNER TO PROVIDE DOOR FOR DIRECT ENTRY FROM OUTSIDE OF BUILDING AT ALL TIMES.

**DOUBLE DETECTOR CHECK VALVE
ASSEMBLY INSIDE BUILDING**

NTS

APPROVAL DATE 10/21/2020	DRAWN SED	CHECKED DS
PLOTTING SCALE NTS	DETAIL NUMBER HWD STANDARD DETAIL 22	

BSJ
10/28/20

