



- PAINT HYDRANT, ABOVE THE BREAKER FLANGE, WITH TWO (2) COATS OF PAINT PER HWD STANDARDS.
- SEE APPROVED MATERIALS LIST.
- FOR HYDRANT RUNS GREATER THAN 50', UPSIZE PIPE AND VALVE TO 8".
- INSTALL BLUE PAVEMENT MARKER IF HYDRANT IS LOCATED WITHIN THE RIGHT-OF-WAY.
- NEATLY STENCIL VALVE DISTANCE ONTO HYDRANT W/2" NUMERALS USING WHITE OR BLACK ENAMEL PAINT AND FACING THE FOOT VALVE.
- SEE STANDARD DETAIL FOR DRAIN KIT ASSEMBLY INSTALLATION.

## FIRE HYDRANT ASSEMBLY

NTS



APPROVAL DATE  
10/21/2020

DRAWN  
SED

CHECKED  
DS

*JSD 10/28/20*

PLOTTING SCALE  
NTS

DETAIL NUMBER  
STANDARD DETAIL 8